

# Results of Routine Testing of L3W YaS

## 1. GENERAL :—

- 1.1 Name of sub-station/Power house ..... Date .....
- 1.2 Name of line ..... Circuit breaker no .....
- 1.3 Details of relay :—  
Sl. No..... Type... .... Make :- Brown-Boveri

## 2. SETTINGS :—

$I_m = \dots \dots \dots$ ,  $U_m = \dots \dots \dots$ ,  $Z_{AZ\theta} = \dots \dots \dots$ , Ohms/ph,  $Z_A = \dots \dots \dots$   
 $PTA\Delta = \dots \dots \dots$ ,  $PTAW = \dots \dots \dots$ ,  $PT_{rh} = \dots \dots \dots$ ,  $MCoS\phi = \dots \dots \dots$   
 $PT_{sE} = \dots \dots \dots$ ,  $PT_{rW} = \dots \dots \dots$ ,  $RLV = \dots \dots \dots$ , Time  $T_s = \dots \dots \dots$   
 $wL = \dots \dots \dots$ ,  $u = \dots \dots \dots$ ,  $C = \dots \dots \dots$

### 2.1 COVERED IMPEDANCES :—

	Primary value in ohms	Secondary value in ohms
Zone I		
Zone II		
Zone III		
Zone IV		

## 3. CHECKING OF D.C. SEQUENCE :—

D.C. sequence checked, the results are O.K.

## 4. NOTE :—

- 4.1 Remove D.C. (by removing D.C. plug)  
 4.2 Short C.T. circuit (by dropping links 1, 2, 3, 4)  
 4.3 Carrier links 14, 16, 17 are to be kept open.

## 5. ACCURACY OF IMPEDANCE MEASUREMENTS RELAYS :

Nature of faults	Relay Z		ZAR	ZAS	ZAT
	Setting ohms/ph	Theoretical value from annex 6a	% Z Measured value	% Z Measured value	% Z Measured value
Double phase faults (switch position, $g_1$ )					
Single phase faults (switch position $g_2$ )					
Three phase faults (switch position $g_3$ )					

6. D.C. INTERLOCKED SUPPLY CHECKED AND IT IS .....

7. ACCURACY OF TIMER CHECKED

Continued ....

CHECKING OF CM RELAY :

Nature of fault	Step I-II			Step II-III			Step III-IV			Step IV-V		
	Settings I	Theoretical value %Z from annex 6b	Measured value %Z R   S   T	Settings II	Theoretical value %Z from annex 6b	Measured value %Z R   S   T	Settings III	Theoretical value %Z from annex 6b	Measured value %Z R   S   T	Settings IV	Theoretical value %Z from annex 6b	Measured value %Z R   S   T
1. Ph. Fault (g <sub>2</sub> )												
2. Ph. Fault (g <sub>1</sub> )												
3. Ph. Fault (g <sub>3</sub> )												

Checking of L6ft. Relay :— (Accuracy of CM 3 relay)

Settings cuo = ..... PT aH = ..... PT aS = .....  
wl = ..... C = .....

Nature of fault	Hg <sub>3</sub> (Trans.)	Theoretical value %Z (Annex 6b)	Measured value R S T	Remarks
Single phase fault (Switch on g <sub>2</sub> )	Setting %V			

Countersigned by

Executive Engineer (T & C)

Tested by

Assistant Engineer (T & C)